



PLECS

DEMO MODEL

Double Fed Induction Generator Wind Turbine

Last updated in PLECS 4.7.1

www.plexim.com

- ▶ Request a PLECS trial license
- ▶ Check the PLECS documentation

1 Overview

This demonstration shows a 2 MW wind power system with a doubly-fed induction generator (DFIG), where the interaction between the electrical circuit and the mechanical drivetrain during normal operation, as well as fault conditions, are investigated. The PLECS thermal and magnetic physical domains are integrated into the model as well.

Note This model contains model initialization commands that are accessible from:

PLECS Standalone: The menu **Simulation + Simulation Parameters... + Initializations**

PLECS Blockset: Right click in the **Simulink model window + Model Properties + Callbacks + InitFcn***




Figure 1: Schematic of the DFIG wind turbine model in PLECS

2 Model

A 2 MW DFIG wind turbine model has been designed in PLECS and a top-level diagram is shown in Fig. 1. The components of the system are from the libraries for the different physical domains, including electrical, magnetic, mechanical, as well as signal processing and control systems.

2.1 Electrical Domain

The wound-rotor induction machine, power electronic converter and LCL filter, as well as the long distance transmission line and medium-voltage (MV) grid are all modeled in the electrical domain:

- Induction machine:** The wound-rotor induction machine model (the Induction Machine (Slip Ring) library component) is based on a stationary reference frame (Clarke transformation). A proper implementation of the Clarke transformation facilitates the connection of external inductances in series with the stator windings, which in this case are the leakage inductances of the transformer. External inductors cannot be connected to the rotor windings though, due to the fact that the electrical interfaces there are modeled as controlled current sources.




Figure 2: The PLECS induction machine component

- Power converter:** The back-to-back converter topology is selected for control of the rotor power, where two three-leg, two-level IGBT bridges are connected together via a DC-link capacitor. For protection reasons a chopper IGBT and break resistor is connected onto the DC-link to clamp the capacitor voltage to a safe level. The switch will be turned on to discharge the DC-link in the case of over-voltage conditions, and turned off when the voltage falls back to the nominal value. The rotor-side inverter is directly connected to the induction machine's rotor, while the grid-side inverter is connected through an LCL filter to the tertiary winding of the transformer. The IGBTs of the inverters are modeled as ideal switches to guarantee a fast simulation at system level.




Figure 3: Back-to-back converter model

- Filter:** The LCL-type filter is used to smooth the current ripple caused by the PWM modulation of the grid-side inverter. According to the electric grid code for renewable energy generation, a certain THD standard needs to be fulfilled when selecting the inductance and capacitance values. In comparison to the inductor-only filter, the LCL filter is able to suppress the harmonics with much smaller inductance values, and the reduced weight and volume therefore leads to a higher power density. Two resonant frequencies are introduced into the system due to the capacitor, however, which may give rise to stability issues [3].




Figure 4: LCL filter model

- Transmission line:** The wind capacity is strongly influenced by an area's geography. Wind turbines are often placed far from the high voltage-to-medium voltage (HV/MV) sub-station, so the transmission line (normally an underground cable in Europe) that transfers the wind power to the upper-level grid can be tens of kilometers in length. To model a cable of such a long distance, one can either connect multiple PI-sections (capacitor-inductor-capacitor) together in series, or imitate the traveling-

wave behavior of the current and voltage. Both options are provided in the transmission line model found in PLECS and can be selected based on different requirements. The PI-section implementation is intuitive to the user, however, implementing an accurate cable model with it requires many sections. This creates a large number of state variables and may slow down the simulation drastically. The distributed parameter line implementation based on the analytical solution of a traveling wave calculates the delay time of the current or voltage waveform as it propagates from one end of the cable to the other [4], and thus avoids the simulation speed issue related to an increase in state variables. But unlike the PI-section implementation, it models the power losses as lumped resistances, and only the case of symmetrical parameters (e.g. inductance) among the three phases can be modeled.




Figure 5: The PLECS transmission line component

- **MV grid:** The medium-voltage grid is simplified as a three-phase voltage source with a line-to-line voltage of 10 kVrms.




Figure 6: Medium-voltage grid model

2.2 Magnetic Domain

The three-phase, three-winding transformer interfaces the 10 kV medium-voltage grid and the low-voltage terminals of the DFIG. A voltage of 690 V (line-to-line rms) is chosen for the stator-side of the DFIG, while 400 V is used for the rotor-side. In order to eliminate the influence of the zero-sequence component, the windings have Δ -connection at the 10 kV side and a midpoint grounded Y-connection at the low-voltage side. The transformer is modeled using components from the PLECS magnetic library. Magnetic modeling in PLECS offers a powerful method for modeling such components by directly capturing a magnetic circuit using windings and lumped core parts with user-specified geometries. These core parts are represented as lumped permeances and connected with each other in PLECS to create a magnetic circuit [5]. Compared to a co-simulation with a finite element analysis (FEA) tool, where magnetic field analysis is used in the modeling of a magnetic structure, this lumped magnetic circuit method is able to integrate magnetic component models into a system level simulation without causing any substantial increase in simulation time. It also provides more details than modeling a magnetic structure as a purely electrical equivalent circuit, such as non-linearities caused by saturation and hysteresis [6]. In addition, the separation of electrical and magnetic domains provides the user a clearer overview when approaching the actual hardware construction. In this model, the $YY\Delta$ connected three-leg iron core transformer with laminated material is designed and each leg is modeled as a magnetic permeance. Eddy current power losses are represented by magnetic resistance components, which are series-connected to the permeances. The winding components serve as the interface between the electrical and magnetic domains, and leakage fields are modeled with leakage permeances, which are connected in parallel to the windings in the magnetic domain. The complete model is shown in Fig. 7, where the linear permeance core components can be replaced by permeances with saturation or permeances with hysteresis to simulate nonlinear effects.

2.3 Thermal Domain

The semiconductor power losses of the voltage source inverters play an important role in the converter design and can be investigated using PLECS' thermal domain. The PLECS ideal switch approach yields




Figure 7: Transformer model in the PLECS magnetic domain

fast and robust simulations. Accurate conduction and switching loss calculations of the IGBT (and diodes) are achieved via look-up tables that are easily populated with values from data sheets. Fig. 8 demonstrates the two dimensional look-up table for turn-on losses in PLECS, with values obtained from a data sheet [ABB's IGBT module 5SNA1600N170100]. The data sheet provides the curve of the loss energy vs. conducting current, however, for only one blocking voltage condition (1500 V). The loss values for other blocking voltages are linearly extrapolated from 0 V, which has been verified as a acceptable approximation in practice. The dependence of temperature in determining power losses can be established, and the thermal energy transfer characteristics from the junction to the case can be specified.

The PLECS heat sink component absorbs the power losses produced by the components that it contains. It feeds these losses to the cooling system, which is simply modeled in this case as a thermal resistance. The ambient temperature is modeled as a constant temperature sink. During the simulation, the junction temperature of the IGBTs can be monitored to ensure the cooling system is properly sized. Major and minor temperature cycles of the semiconductor dies can be used for life and reliability analyses.

The "Switch Loss Calculator" component is placed within the "Switched model with thermal" subsystem of the inverter models to easily calculate the total losses. For more details, browse the **Help** section of this block.

For more information on thermal modeling and the calculation of device losses and efficiency, see the demo model "Buck Converter with Thermal Model" in the PLECS demo models library.




Figure 8: The PLECS thermal look-up table interface. This shows the turn-on loss table for an IGBT




Figure 9: Cooling system modeled in the thermal domain

Note Thermal simulation results are only available in this demo model if the switched configuration is used inside the initialization commands.

2.4 Mechanical Domain

The variations of the aerodynamic torque on the blades and, consequently, electrical torque on the induction machine's rotor are propagated to the drivetrain of the wind turbine. The resulting fluctuations of the rotational speeds can lead to disturbances in the electrical domain, which depend substantially on the torsional characteristics of the drivetrain to dampen out the oscillations. This model uses a wind source to perturb the mechanical system in order to investigate the effects of such system resonances. The three blades transfer the wind torque to the hub shaft, which is connected to a gearbox. Using a specific gear ratio, the gearbox increases the rotational speed of the hub shaft onto the induction machine's rotor shaft. Friction occurs on the bearings, leading to additional power losses. The mechanical portion of this model consists of a number of lumped inertias [7], which are elastically coupled with each other, as shown in Fig. 10 and Fig. 11.

The inertias of the three blades are shown as J_{blade1} , J_{blade2} , and J_{blade3} , J_{hub} is the hub inertia, $J_{Gearbox}$ is the gearbox inertia, and the inertia of the induction machine's rotor is included under the machine component mask. The spring constants k_{hb1} , k_{hb2} , k_{hb3} , k_{hgb} , and k_{gbg} model the elasticity between adjacent masses and d_{hb1} , d_{hb2} , d_{hb3} , d_{hgb} , and d_{gbg} represent the mutual damping. J_{blade1} , J_{blade2} , and J_{blade3} , J_{hub} , and $J_{Gearbox}$ model the friction in the system, which produces torque losses on individual masses. A wind torque input depending on wind speed and propeller rotational speed is provided. As mentioned previously the typical $C_p(\lambda, \beta)$ curve can be adopted for modeling this, and can be transformed to a surface of wind torque vs. wind speed and turbine rotational speed as shown in Fig. 12.




Figure 10: Complete drivetrain modeled in the PLECS mechanical domain

3 Control Design

A proportional-integral (PI) controller with active damping and anti-windup is utilized for the control of the machine-side and grid-side inverters, as described in [2]. The main task of the machine-side inverter is to regulate the DFIG torque and thus the rotational speed of the rotor, as well as the DFIG reactive power that is injected into the grid via the induction machine's stator windings. The speed control scheme comprises an inner fast current loop that regulates the rotor current and an outer slow speed loop, which provides the reference signal for q-axis current control. A similar structure is utilized for reactive power control. The current control is implemented in a flux-oriented manner, where the rotor current is decomposed into the d- and q-axis in the rotational frame, which are DC values during steady state. For parameter selection the state-space model of the induction machine is derived in a form of complex vectors, where the physical variables have been transformed to the stator-side using the turns ratio:

$$v_s = R_s i_s + \frac{d\Psi_s}{dt} + j\omega_1 \Psi_s,$$

$$v_R = R_R i_R + \frac{d\Psi_R}{dt} + j\omega_2 \Psi_R,$$

where

$$\Psi_s = L_M (i_s + i_R),$$




Figure 11: Propeller drivetrain model




Figure 12: Wind torque vs. wind speed and turbine rotational speed surface

$$\Psi_R = (L_M + L_\sigma) i_R + L_M i_s,$$

$$\omega_2 = \omega_1 - \omega.$$

Note that the stator leakage inductance has been eliminated in the equations above, due to the fact that the stator flux is selected as the reference vector. Graphically the state-space model can be expressed as a circuit schematic for the d- and q-axis, respectively, as shown in Fig. 13. By substituting the equations




Figure 13: State-space model of the induction machine in the rotational frame

for the stator voltage and flux linkage into the one for the rotor voltage, we find that:

$$v_R = (R_R + R_s j\omega_2 L_\sigma) i_R + L_\sigma \frac{di_R}{dt} + E,$$

where the back EMF, E , is equal to:

$$E = v_s - \left(\frac{R_s}{L_M} + j\omega \Psi_s \right).$$

Rewriting the equations in the d-q axes separately yields:

$$v_{Rd} = (R_R + R_s) i_{Rd} - \omega_2 L_\sigma i_{Rq} + L_\sigma \frac{di_{Rd}}{dt} + v_{sd} - \frac{R_s}{L_M} \Psi_s,$$

$$v_{Rq} = (R_R + R_s) i_{Rq} - \omega_2 L_\sigma i_{Rd} + L_\sigma \frac{di_{Rq}}{dt} + v_{sq} - \omega \Psi_s.$$




Figure 14: D-axis current controller of the machine-side inverter




Figure 15: DQaxis current controller of the machine-side inverter

The two equations above express the state-space model of the rotor current i_R with the rotor voltage v_R as the input variable. Variation of the back EMF may lead to tracking error, and like the cross coupling term from the other orthogonal axis, can be regarded as a disturbance. Such disturbances can be suppressed effectively via feedforward control. The resulting structure of the current controller is shown in Fig. 14 and Fig. 15. The output of the current controller will be given to the space vector pulse-width modulator (SVPWM) to generate the PWM signals for the three-phase terminal of the IGBT bridge.

The stator flux linkage Ψ_s is present in the feed-forward term of the back EMF, however this is not easily measured in the hardware implementation. Therefore an estimation approach using the stator current and voltage as input variables has been adopted instead [8]. Based on the implemented state-space model, the proportional and integral gains of the PI controller are selected as:

$$K_p = \alpha_c L_\sigma,$$

$$K_i = \alpha_c (R_R + R_s + R_a),$$

where α_c is the desired bandwidth of the closed-loop system. It can be related to the rise time of a step response as:

$$\alpha_c = \frac{\ln(9)}{t_{\text{rise}}}.$$

Also, a virtual resistance R_a has been introduced to make sure that the disturbance (e.g. the estimation error of the back EMF) will be dampened with the same time constant as the forward control scheme, which is also known as “active damping”. R_a is defined as:

$$R_a = \alpha_c L_\sigma - R_R - R_s.$$

The reference signal for the q-axis current is provided by the speed controller, whose design is based on the simplified mechanical model of the wind turbine:

$$\frac{J_{\text{total}}}{n_p} \frac{d\omega}{dt} = T_e - T_{\text{wind}},$$




Figure 17: Reactive power controller of the machine-side inverter

$$K_{iQ} = \frac{\alpha_Q}{3\omega_1 \Psi_s},$$

where α_Q is the desired bandwidth. Considering the fact that the stator resistance is usually small, the stator flux Ψ_s in the equation above can be replaced by $\omega_1 \cdot V_{g,\text{nom}}$, where $V_{g,\text{nom}}$ is the nominal grid peak voltage on the stator-side of the induction machine. The grid-side inverter maintains the DC-link voltage at a constant level. Similar to the machine-side inverter, a two-loop configuration is set up for the grid-side inverter with an outer loop for voltage control and an inner loop for current control. The current control loop is implemented in the d-q frame and is synchronized with the grid voltage, where the orientation reference is provided by a phase-locked loop (PLL).

An LCL filter is selected for the AC output terminal. Currently, this type is considered to be an attractive solution to attenuate the switching frequency current ripple compared to the pure inductance filter due to the lower size of the magnetic components. Given the maximum ripple current I_{hfpp} (peak-to-peak) on the inverter output terminal, the inductances L_{f1a} , L_{f1b} , and L_{f1c} in Fig. 4 can be determined by:

$$L_{f1} = \cos(\pi/6) \cdot \frac{2/3 V_{\text{dc}} - V_{g3}}{I_{\text{hfpp}} f_{\text{sw}}} \cdot \frac{\sqrt{3} V_{g3}}{V_{\text{dc}}},$$

where V_{g3} is the nominal voltage (peak value) on the tertiary winding of the transformer. The ratio between the inductance values L_{f1} and L_{f2} can be treated as an operational variable for optimization of overall size and cost. In this model it is assumed that a value of $L_{f2} = 0.15L_{f1}$ has been chosen as a result of the optimization. According to the THD requirement for the grid operator, which is the ratio between the peak-to-peak value of the nominal grid current I_{gpp} and ripple I_{hfpp} , the capacitance value can be calculated as:

$$C_f = \frac{1}{L_{f2}(2\pi f_{\text{sw}} 10^{\frac{k_A}{40dB}})},$$

where the attenuation k_A is given as:

$$k_A = 20 \log_{10} \left(THD \frac{I_{\text{gpp}}}{I_{\text{hfpp}}} \right).$$

4 Simulation

The electrical parameters of the doubly-fed induction machine according to [10] are listed below in Table 1, where the rotor parameters have been converted to the stator-side using the turns ratio.

The transformation from the physical parameters in Table 1 above to the ones of the equivalent circuit in Fig. 13 is achieved via the following equations:

Table 1: Electrical parameters of the induction machine

Pole pairs n_p	2
Turns ratio n_s/n_p	1/2.6
Stator leakage $L_{s\sigma}$	0.12 mH
Rotor leakage $L'_{r\sigma}$	0.05 mH
Main inductance L_m	2.9 mH
Stator resistance R_s	0.022 Ω
Rotor resistance R'_r	0.0018 Ω

$$L_M = \gamma L_m$$

$$L_{\text{sigma}} = \gamma L_{s\sigma} + \gamma^2 L'_{r\sigma}$$

$$R_R = \gamma^2 R_r,$$

where,

$$\gamma = (L_{s\sigma} + L_m)/L_m.$$

As a result of the aforementioned design process for the LCL filter, the inductance value of the converter-side as well as grid-side inductors are calculated as 0.48 mH and 0.044 mH, respectively, while the capacitance value is 57 mF. For connection from the turbine transformer to the 10 kV stiff grid, the model of a 10 kV medium-voltage cable (type N2XSF2Y [10]) is established using the distributed parameter line component. The resistance, self-inductance and neutral capacitance per unit length are 0.206 Ω/km , 0.363 mH/km and 0.25 mF/km, respectively. The mutual inductance and coupling capacitance are assumed to be one third of the self and neutral values. The mechanical parameters of an example 2 MW wind turbine are provided by [10] and [7] in per unit values, and the transformation from per unit to real values has been described in [11].

During the simulation the following example scenarios are executed successively:


**Figure 18: Voltage profiles during the event of a grid fault**

Table 2: Mechanical parameters of the wind turbine

Rotor inertia J_g	75 kg m ²
Gearbox inertia J_{gb}	4.26 · 10 ⁵ kg m ²
Hub inertia J_{sh}	6.03 · 10 ⁴ kg m ²
Blade inertia J_b	1.13 · 10 ⁶ kg m ²
Rotor friction D_g	0.81 Nm s/rad
Gearbox friction D_{gb}	1.78 · 10 ⁴ Nm s/rad
Hub friction D_h	8.11 · 10 ³ Nm s/rad
Blade friction D_b	1.08 · 10 ³ Nm s/rad
Gearbox to rotor stiffness k_{gbg}	4.67 · 10 ⁷ Nm/rad
Hub to rotor stiffness k_{bhgb}	1.39 · 10 ¹ Nm/rad
Blade to hub rotor stiffness k_{bh}	1.07 · 10 ¹ Nm/rad
Gearbox to rotor damping d_{gbg}	0.81 · 10 ³ Nm s/rad
Hub to gearbox damping d_{hgb}	2.84 · 10 ⁶ Nm s/rad
Blade to hub rotor damping d_{bgb}	3.24 · 10 ⁶ Nm s/rad




Figure 19: Averaged model of the three-phase inverter

- **Initial state:** At the simulation start the generator operates at 157 rad/s, which is synchronous to the grid frequency. Most of the generated active power is injected into the grid via the stator winding of the induction machine, while due to the zero slip condition, virtually no power flows through the rotor except for the resistive losses. The reactive power generation is not activated yet at this stage.
- **Acceleration:** At 3 s the rotation speed of the turbine is accelerated to 175 rad/s via a step jump on the reference input of the speed controller, to achieve maximum power generation under the given wind speed of 12 m/s. As mentioned previously, the external MPPT loop utilized in a practical implementation is not present in this model. The step change of the speed reference is just a fictional one




Figure 20: Mechanical oscillation at startup of the wind turbine

which sets up the machine for an extreme test case to prove the system's stability.

- **Grid fault:** At 12 s a three-phase short circuit fault occurs on the 10 kV medium-voltage grid, which is modeled using a controllable voltage source. Three fault options regarding the residual voltage's profile can be chosen. The first option is a 0.2 s zero voltage sag, while the other two options are described in the 2007 German Transmission Code Standards [9], as Fig. 18 shows.

The duration of the simulation has been set to 25 s, which should be sufficient to investigate the reaction from the overall system standpoint, especially considering the mechanical part. This timeframe is however, relatively long compared to the switching frequency of the back-to-back converter (5 kHz). If the current ripple due to the switching frequency and power losses of the semiconductors are not of interest for certain applications, an averaged converter model can be used to speed up the simulation. The averaged model is established via controlled voltage and current sources, as shown in Fig. 19, and can be optionally selected from the mask.

By simulating the scenarios described above, the robustness of the design is observed and improvements can be made, namely with the control techniques. The various parameters in the system are chosen to provide desirable results during the entire operating range of the turbine. At the start of the simulation, a damped oscillation can be observed due to the elastic and lossy coupling between the mechanical parts, as shown in Fig 20.

As the step change for the speed reference is applied, the speed controller generates a torque reference for the q-axis current controller of the machine-side inverter which is higher than the wind torque applied on the blades, thus the turbine accelerates. The behavior of rotational speed and torque is illustrated in Fig 21, where the speed values of the hub and blades have been converted to the high-speed side of the gearbox (the induction machine shaft side). After approximately 7 s, the electrical torque of the induction machine and the wind torque enter a balanced state and the rotational speed remains




Figure 21: Mechanical reaction during acceleration

175 rad/s. As a result 11 % slip rate, about 10 % of the real power will now be transmitted out of the rotor winding, as shown in Fig 22.

If the averaged model is chosen for the simulation, the electrical torque waveform will be ripple-free and match the mean value of the torque waveform for the model with ideal switches, as seen in Fig 23.

To evaluate the performance of the wind turbine during a worst case grid-side fault condition, known as “low voltage ride through” (LVRT) behavior, and the borderline 2 scenario from Fig 19, is set up for the voltage profile during the grid short circuit. As the grid voltage falls to zero at 14 s, the stator flux decreases to an extremely small value, where the induction machine is no longer able to generate electrical torque. When this happens, the power absorbed by the blades from the wind will be completely stored in the rotating mechanical components in the form of kinetic energy, and the turbine will accelerate. After the voltage starts to recover due to the clearing of the fault after 0.15 s, the stator flux recovers gradually such that electrical torque can be produced again to counteract the driving torque from the wind. As a result the speed will be restored back to the reference value 175 rad/s, as shown in Fig 24.

The electrical transient of voltage and current on the primary winding (10 kV side) of the transformer, as well as the DC-link voltage of the back-to-back converter, is displayed in Fig 25. The AC voltage on the transformer terminal does not fall to zero as the grid is stiff due to the inductance of the transmission line in between. The AC current exhibits a large peak immediately after the fault occurs, and then is maintained below a certain range because of the saturated input of the current controller. Due to the voltage drop at the transformer’s tertiary winding, the grid-side inverter is also no longer able to transfer power, so the DC-link voltage is nearly uncontrolled in the first seconds after the fault. The DC-link capacitor is then charged or discharged purely by the machine-side inverter. The transient of the active power from the machine-side inverter can be analyzed using the q-axis equivalent circuit in Fig 13.

Therefore, nearly the identical amount of active power as before the fault charges the capacitor, such




Figure 22: Active and reactive power flow out of the stator and rotor during acceleration




Figure 23: Electrical torque of the induction machine in the averaged model

that the voltage rises quickly. The voltage will not exceed 108 % of the nominal voltage (950 V), however, and is clamped to a safe level due to the activation of the chopper circuit. The speed controller will then deliver a higher reference value for the q-axis current to the current controller to pull the rotational speed back to 175 rad/s although it is unsuccessful.

As a result, the current controller applies a q-axis voltage v_{Rq} of opposite polarity compared to before the fault, because of the nearly zero value of the back EMF $\omega \Psi_s$. Hence, the active power becomes neg-




Figure 24: Mechanical transient during the grid fault




Figure 25: Electrical transient during the grid fault




Figure 26: Comparison of the DC-link voltage between the averaged and switched inverter model

active for a short time, and the capacitor is discharged and the voltage falls until approximately 12.3 s. After that, as the grid voltage recovers, the back EMF $\omega \Psi_s$ rises so v_{Rq} changes its polarity back to what it was before the fault, and the active power becomes positive, effectively re-charging the capacitor. At this moment the grid-side inverter is still not able to transfer a large amount of power, therefore the net power flowing into the capacitor is still in surplus and the voltage rises further. Because of the chopper circuit, the voltage oscillates between the limitation and the nominal value in the following several seconds, until the grid voltage totally recovers and the grid-side inverter is again able to transfer enough power.

If this fault scenario is simulated with the averaged inverter model, the result shows slight differences from that with the full switching model, because the switching period is comparable to the transient during the fault condition. This issue should be considered if the averaged model is used to accelerate the simulation speed. As shown in Fig 26, the lighter red curve corresponds to the switched model.

The thermal information, including the junction temperature and losses for one IGBT over the course of the total simulation, is depicted in Fig 27. Note that the switched inverter model must be enabled in order to view these waveforms.

References

- [1] J. Schönberger, “Modeling a DFIG wind turbine system using plects,” in *Application Note of Plexim GmbH*.
- [2] A. Petersson, *Analysis, Modeling and Control of Doubly-Fed Induction Generators for Wind Turbines*. PhD thesis, Chalmers University of Technology, Göteborg, Sweden, 2005.
- [3] R. Teodorescu, M. Liserre, and P. Rodriguez, *Grid Converters for Photovoltaic and Wind Power Systems*. Aalborg: John Wiley & Sons, Ltd, 1. edition ed., 2011.
- [4] H. Dommel, “Digital computer solution of electromagnetic transients in single and multiple networks”, in *IEEE Transactions on Power Apparatus and Systems*, pp. Vol. PAS88, No. 4.
- [5] J. van Vlerken and P. Blanken, “Lumped modeling of rotary transformers, heads and electronics for helical-scan recording”, in *Control and Modeling for Power Electronics (COMPEL), IEEE 13th Workshop on, 2012*.
- [6] J. Allmeling, W. Hammer, and J. Schönberger, “Transient simulation of magnetic circuits using the permeance-capacitance analogy”, in *Control and Modeling for Power Electronics (COMPEL), IEEE 13th Workshop on, 2012*.




Figure 27: Junction temperature of one IGBT and total power losses

- [7] S. M. Muyeen, M. H. Ali, R. Takahashi, T. Murata, J. Tamura, Y. Tomaki, A. Sakahara, and E. Sasano, "Blade-shaft torsional oscillation minimization of wind turbine generator system by using statcom/ess", in *Power Tech, 2007 IEEE Lausanne*, pp. 184-189.
- [8] Analog Devices Inc., "Flux and speed estimation for induction machines", in *Application Note AN331-29*.
- [9] Verband der Netzbetreiber VDN e.V. beim VDEW, "Network and system rules of the German transmission system operators", in *Transmission Code*, 2007.
- [10] T. Thiringer, J. Paixao, and M. Bongiorno, "Monitoring of the ride-through ability of a 2 MW wind turbine in Tvaaker, Halland", in *Elforsk rapport 09:26*.
- [11] A. G. G. Rodriguez, A. G. Rodriguez, and M. B. Payan, "Estimating wind turbines mechanical constants", in *International Conference on Renewable Energies and Power Quality - ICREPQ*, Sevilla, 2007.

Revision History:

PLECS 4.3.1	First release
PLECS 4.5.5	Updating the documentation and graphics
PLECS 4.7.1	Updated the model with the Switch Loss Calculator

How to Contact Plexim:

☎	+41 44 533 51 00	Phone
	+41 44 533 51 01	Fax
✉	Plexim GmbH Technoparkstrasse 1 8005 Zurich Switzerland	Mail
@	info@plexim.com	Email
	http://www.plexim.com	Web

PLECS Demo Model

© 2002–2023 by Plexim GmbH

The software PLECS described in this document is furnished under a license agreement. The software may be used or copied only under the terms of the license agreement. No part of this manual may be photocopied or reproduced in any form without prior written consent from Plexim GmbH.

PLECS is a registered trademark of Plexim GmbH. MATLAB, Simulink and Simulink Coder are registered trademarks of The MathWorks, Inc. Other product or brand names are trademarks or registered trademarks of their respective holders.